

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.1051/2025

Dated: 20/05/2025

It is certified that an inspection team headed by AJAY KUMAR (Name of Officers with designation) from...
ASSISTANT ENGINEER WATER SUPPLY AND SANITATION BIKANER (PHED)

Inspected the...NOBLE INTERNATIONAL SCHOOL, LUNKARANSAR, BIKANER

(Name & Address of the school) on17/05/2025.....(date of inspection) and on the basis
of Water Test Report (Attached) bearing no....889..... dated...20/05/2025..... Of OFFICE OF
SENIOR CHEMIST LABORATORY, BIKANER (PHED Lab)certified that the

NOBLE INTERNATIONAL SCHOOL (Name of school) has safe drinking water facilities for the
students and members of staff of the institution. School is also maintains the hygienic sanitation
condition in the school building & the campus as per norms prescribed by the Central/ State/
U.T. Govt.

This certificate is valid till...19/05/2028

अधिश. प्र. अभि. विभाग
जन्. स्वा. अभि. विभाग
जिला बीकानेर (राज.)

Signature with Seal:
Name :
Designation :
Name & Address of the Office/Department:.....

To
NOBLE INTERNATIONAL SCHOOL
LUNKARANSAR, BIKANER
(Name & Address of the Institution)

Note: The certificate is to be issued by
authorized officer/PHED Lab/local bodies



Public Health Engineering Department
Office Of Senior Chemist
Bikaner



No. Lab/Tech(Chem)/2024-25/ 889

Dated : 20/5/25

REPORT OF THE CHEMICAL EXAMINATION OF WATER

R.P. DHAKA

District: Bikaner

NOBLE INTERNATIONAL SCHOOL

Block: Lunkaransar

TEH. LUNKARANSAR, BIKANER

Reference : L C S Letter No.

Dated: 20-05-2025

Date of Receipt : 20-05-2025

Exam. Date: May-25

Date of Receipt: 20-05-2025

LS No.	BIS 10500; 2012 Drinking Water Standards	DL-Bhl / Rt/ 24-25/ 1524					
Panchyat							
Village/City		Lunkaransar					
Habitation	Maximum Desirable Limit	Maximum Permissible Limit	Lunkaransar				
Source			Noble International School,Lunkaansar				
Date of Collection			17-05-2025				
Name of Sample Taker			Divya teacher				

Note : - All results except pH are in mg/L.

1	pH	6.5-8.5	NR	7.41			
2	TDS	500	2000	449			
3	Turbidity	1	5	0			
4	Total Alkalinity (As CaCO3)	200	600	215			
5	Total Hardness (As CaCO3)	200	600	202			
6	Chloride	250	1000	121			
7	Sulphate	200	400	47			
8	Nitrate	45	NR	1.7			
9	Calcium Hardness	188	500	133			
10	Magnesium Hardness	125	417	69			
11	Fluoride	1	1.5	0.51			
12	Conductivity	-	-	670			
13	Sodium	-	-	32			
14	Potassium	-	-	3			

Samples Not Collected by Laboratory
Not for Legal Purposes

Senior Chemist
PHED District Laboratory
Bikaner
Dated :

No. Lab/Tech(Chem)/2024-25/
Copy to - Supt. Chemist Chemist PHED Lab, Ajmer

Senior Chemist
PHED District Laboratory
Bikaner